

### Project Description

File Name ..... 323 - Att Pond 3 East PIPES ONLY.SPF

### Project Options

Flow Units ..... CMS  
 Elevation Type ..... Elevation  
 Hydrology Method ..... EPA SWMM  
 EPA SWMM Infiltration Method ..... SCS Curve Number  
 Link Routing Method ..... Hydrodynamic  
 Enable Overflow Ponding at Nodes ..... YES  
 Skip Steady State Analysis Time Periods ... NO

### Analysis Options

Start Analysis On ..... Apr 25, 2016 00:00:00  
 End Analysis On ..... Apr 26, 2016 00:00:00  
 Start Reporting On ..... Apr 25, 2016 00:00:00  
 Antecedent Dry Days ..... 0 days  
 Runoff (Dry Weather) Time Step ..... 0 00:00:10 days hh:mm:ss  
 Runoff (Wet Weather) Time Step ..... 0 00:00:10 days hh:mm:ss  
 Reporting Time Step ..... 0 00:00:10 days hh:mm:ss  
 Routing Time Step ..... 0.5 seconds

### Rainfall Details

SN	Rain Gage ID	Data Source	Data Source ID	Rainfall Type	Rain Units	State	County	Return Period (years)	Rainfall Depth (mm)	Rainfall Distribution
1		Time Series	25yr RI	Cumulative	mm	None	None	25	72.10	South Africa 24-hr, Type 2

**Subbasin Hydrology****Subbasin : Post-Attenuation****Input Data**

Area (ha) ..... 20.27  
 Impervious Area (%) ..... 85.00  
 Weighted Curve Number ..... 86.79  
 Conductivity (mm/hr) ..... 4.0000  
 Drying Time (days) ..... 7.00  
 Average Slope (%) ..... 1.0000  
 Equivalent Width (m) ..... 150.00  
 Impervious Area  
     *Manning's Roughness* ..... 0.0150  
 Pervious Area  
     *Manning's Roughness* ..... 0.1500  
 Curb & Gutter Length (m) ..... 0.00  
 Rain Gage ID ..... 323-Wellington

**Composite Curve Number**

Soil/Surface Description	Area (ha)	Soil Group	Curve Number
Paved roads with curbs & sewers	3.06	C	98.00
50 - 75% grass cover, Fair	10.56	C	79.00
Urban commercial, 85% imp	6.65	C	94.00
Composite Area & Weighted CN	20.27		86.79

**Subbasin Runoff Results**

Total Rainfall (mm) ..... 72.03  
 Total Runon (mm) ..... 0.00  
 Total Evaporation (mm) ..... 0.0000  
 Total Infiltration (mm) ..... 5.3520  
 Total Runoff (mm) ..... 62.17  
 Peak Runoff (cms) ..... 1.39  
 Weighted Curve Number ..... 86.79  
 Time of Concentration (days hh:mm:ss) ..... 0 03:58:14

**Subbasin : Post-Development****Input Data**

Area (ha) ..... 20.27  
 Impervious Area (%) ..... 85.00  
 Weighted Curve Number ..... 86.79  
 Conductivity (mm/hr) ..... 4.0000  
 Drying Time (days) ..... 7.00  
 Average Slope (%) ..... 1.0000  
 Equivalent Width (m) ..... 150.00  
 Impervious Area  
     *Manning's Roughness* ..... 0.0150  
 Pervious Area  
     *Manning's Roughness* ..... 0.1500  
 Curb & Gutter Length (m) ..... 0.00  
 Rain Gage ID ..... 323-Wellington

**Composite Curve Number**

Soil/Surface Description	Area (ha)	Soil Group	Curve Number
Urban commercial, 85% imp	6.65	C	94.00
Paved roads with curbs & sewers	3.06	C	98.00
50 - 75% grass cover, Fair	10.56	C	79.00
Composite Area & Weighted CN	20.27		86.79

**Subbasin Runoff Results**

Total Rainfall (mm) ..... 72.03  
 Total Runon (mm) ..... 0.00  
 Total Evaporation (mm) ..... 0.0000  
 Total Infiltration (mm) ..... 5.3520  
 Total Runoff (mm) ..... 62.17  
 Peak Runoff (cms) ..... 1.39  
 Weighted Curve Number ..... 86.79  
 Time of Concentration (days hh:mm:ss) ..... 0 03:58:14

**Subbasin : Pre-Development**

**Input Data**

Area (ha) ..... 20.27  
 Impervious Area (%) ..... 25.00  
 Weighted Curve Number ..... 79.00  
 Conductivity (mm/hr) ..... 4.0000  
 Drying Time (days) ..... 7.00  
 Average Slope (%) ..... 1.0000  
 Equivalent Width (m) ..... 150.00  
 Impervious Area  
     *Manning's Roughness* ..... 0.0150  
 Pervious Area  
     *Manning's Roughness* ..... 0.1500  
 Curb & Gutter Length (m) ..... 0.00  
 Rain Gage ID ..... 323-Wellington

**Composite Curve Number**

Soil/Surface Description	Area (ha)	Soil Group	Curve Number
50 - 75% grass cover, Fair	20.27	C	79.00
Composite Area & Weighted CN	20.27		79.00

**Subbasin Runoff Results**

Total Rainfall (mm) ..... 72.03  
 Total Runon (mm) ..... 0.00  
 Total Evaporation (mm) ..... 0.0000  
 Total Infiltration (mm) ..... 29.6610  
 Total Runoff (mm) ..... 30.96  
 Peak Runoff (cms) ..... 0.26  
 Weighted Curve Number ..... 79.00  
 Time of Concentration (days hh:mm:ss) ..... 0 06:53:10

## Storage Nodes

### Storage Node : Attenuation Chamber

#### Input Data


Invert Elevation (m) ..... 1001.00  
 Max (Rim) Elevation (m) ..... 1003.10  
 Max (Rim) Offset (m) ..... 2.10  
 Initial Water Elevation (m) ..... 1001.00  
 Initial Water Depth (m) ..... 0.00  
 Ponded Area (m<sup>2</sup>) ..... 5200.00  
 Evaporation Loss ..... 0.00

#### Storage Area Volume Curves

Storage Curve : POND

Stage (m)	Storage Area (m <sup>2</sup> )	Storage Volume (m <sup>3</sup> )
0	0	0.000
0.25	4400	550.00
1.5	5200	6550.00
2.5	5200	11750.00

### Storage Area Volume Curves



**Storage Node : Attenuation Chamber (continued)**

**Outflow Weirs**

SN Element ID	Weir Type	Flap Gate	Crest Elevation (m)	Crest Offset (m)	Length (m)	Weir Total Height (m)	Discharge Coefficient
1	Overflow Weir	Rectangular	No	1002.71	1.71	4.00	0.10 1.84

**Outflow Orifices**

SN Element ID	Orifice Type	Orifice Shape	Flap Gate	Circular Orifice Diameter (mm)	Rectangular Orifice Height (mm)	Rectangular Orifice Width (mm)	Orifice Invert Elevation (m)	Orifice Coefficient
1	25yr Orifice	Side	CIRCULAR	No	300.00		1002.30	0.61
2	5yr Orifice	Side	CIRCULAR	No	250.00		1001.00	0.61

**Output Summary Results**

Peak Inflow (cms)	1.39
Peak Lateral Inflow (cms)	1.39
Peak Outflow (cms)	0.23
Peak Exfiltration Flow Rate (cmm)	0.00
Max HGL Elevation Attained (m)	1002.60
Max HGL Depth Attained (m)	1.6
Average HGL Elevation Attained (m)	1001.72
Average HGL Depth Attained (m)	0.72
Time of Max HGL Occurrence (days hh:mm)	0 15:14
Total Exfiltration Volume (1000-m <sup>3</sup> )	0.000
Total Flooded Volume (ha-mm)	0
Total Time Flooded (min)	0
Total Retention Time (sec)	0.00